



Central Office: 505 Silas Deane Highway, Wethersfield, CT 06109 Phone (860) 721-2822 Fax (860) 721-2823
 Berlin: 240 Kensington Road, Berlin, CT 06037 Phone (860) 828-7017 Fax (860) 828-9248
 Newington: 131 Cedar Street, Newington, CT 06111 Phone (860) 665-8586 Fax (860) 665-8533
 Rocky Hill: 761 Old Main Street, Rocky Hill, CT 06067 Phone (860) 258-2770 Fax (860) 258-2767
 www.ccthd.org

Public Swimming Pool Inspection Form

Name of Facility:		Date of Inspection:	
Address:		Town:	
Owner/Operator:		Phone:	
Type of pool:	Pool Capacity (Gals.):	Type of Filter:	

Total Alkalinity (80-100 ppm ^a , 100-120 ppm ^b)	Temperature (78 -82 F)
Calcium Hardness (200-400 ppm ^c , 150 – 250 ppm ^d)	pH (7.2-7.8)
Free Chlorine (0.8 ppm min.) (0.8 – 3.0 ppm rec.)	
Total Chlorine	Whirlpool Free Chlorine (1.0 mg/l)
Combined Chlorine less than (0.2 ppm)	Whirlpool temp. (not greater than 104° F)

General Observations	S	U	Required Signs (letters min 4" high)	S	U
Clarity of Pool			No Lifeguard On Duty (pool)		
Fill faucet air gapped			Directions to telephone /1st aid kit (pool entrance)		
Water level			Emergency numbers posted (pool + at phone)		
Surface and bottom clean			Communicable Disease		
Raised Life Guard Stand			No Spitting or Blowing Nose		
Supervisory Person Appointed			No Running/Rough Play (pool + dressing rooms)		
Recirculation System			All Persons Must Shower		
Skimmers, overflow gutters, baskets, weirs			No Diving in Shallow Area (pool)		
Inlet flows			Whirlpool Safety Signs (adjacent to spa)		
Safety drains covered and clear			Elderly Persons/Medications/Alcohol		
Flow gage operational, Rate = _____ gal per min.			Low Blood Pressure/Don't Use Alone		
Turn-over rate: (Pool Capacity/Gal per min./60)			Unsupervised Children/Time Limit		
pool (1 circulation in 8 hr.) = _____			Bathroom		
whirlpool (1 circulation in .5hr.) = _____			Showers/toilet/sinks/clean		
wading pool (1 circulation in 1-2 hrs.) _____			Floor disinfected		
Wading pool, two bottom drains			Mechanical vent/or operable window		
Hair catcher clear			Soap, towels, toilet paper		
Backwash, single sight glass, air gap, disposal			Fixtures working properly		
Disinfection			Safety		
Auto Chlorinator Type:			Fencing min 4 ft. high		
Adequate quantity of chlorine properly stored			Self – closing /latching gate		
Pool test kit (D.P.D.) provided			Depth marked (rim, sides, min. and max. depth)		
Pool deck clean/disinfected			Depth marker wading pool (min. one on rim)		
Records kept for chlorine and ph			Depth marker whirlpool (min. two)		
(a) For calcium, lithium, or sodium hypochlorite			Ring buoy with min. 50' line		
(b) For sodium dichlor, trichlor, chlorine gas, BCDMH			12' Mounted life pole or shepherd's crook		
(c) For pools and water parks			Safety stripes, stairs/mid depth		
(d) Spas			Telephone in pool area		
			First aid kit available		

Comments: _____

Signed: Inspector

Signed: Operator

